Metcalf Energy Center, LLC

1 Blanchard Road
Coyote, CA 95013

July 25, 2017

Director of Compliance and Enforcement
Bay Area Air Quality Management District
375 Beale Street, Suite 600
San Francisco, CA 94105-2097
Attn: Title V Reports

Re: Metcalf Energy Center #B2183
Title V CEMS Semi-Annual Monitoring Report
Reporting Period: January 1 – June 30, 2017

To Whom It May Concern:

Enclosed is the Title V CEMS Semi-Annual Monitoring Report for the Metcalf Energy Center ("MEC") for the reporting period from January 1 – June 30, 2017.

MEC is currently in compliance with the District CEMS regulations. MEC maintained compliance with the monitoring requirements listed in the Title V permit for MEC during this reporting period.

By signing this report I am certifying that based on information and belief formed after reasonable inquiry, the statements and information in the attached report are true, accurate, and complete.

If you have any questions or require additional information, do not hesitate to contact Rosemary Silva, EHS Specialist, at (408) 361-4954.

Sincerely,

Terry Mahoney
General Manager and
Designated Representative/Responsible Official
Metcalf Energy Center, LLC.

Enclosures: Title V Semi-Annual Report

cc:	Barbara McBride	Calpine Corp
	David Williams	Calpine Corp
	Katherine Piper	Calpine Corp
	Region 9	EPA

Metcalf Energy Center
Title V CEMS Semi-Annual Monitoring Report
January 1, 2017 – June 30, 2017.

Table VII - A

Applicable Limits and Compliance Monitoring Requirements

S-1, GAS TURBINE #1

S-2, GAS TURBINE #2

Type of Limit	Citation of Limit	FE Y/N	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
							Yes	No
NOx	BAAQMD 9-3-303	N	125 ppm	BAAQMD 1-520.1	C	CEM	X	
NOx	BAAQMD 9-9-301.1.3	N	9 ppmv @ 15% O2, dry	BAAQMD 9-9-501	C	CEM	X	
NOx	SIP 9-9-301.3	Y	9 ppmv @ 15% O2, dry	SIP 9-9-501	C	CEM	X	
NOx	BAAQMD 9-9-301.2	N	0.15 LB/MMBTU or 5 ppmv	BAAQMD 9-9-501	C	CEM	X	
NOx	NSPS, 40 CFR 60.332 (a)(1)	Y	75 ppmv @ 15% O2, dry, 4-hour rolling average	NSPS 40 CFR 60.334(c.)	C	CEM	X	
		Y	None	40 CFR 75.10	C	CEM	X	
NOx	BAAQMD condition #18310, part 20a	Y	19.2 lb/hr for each turbine/HRSG powertrain, except during turbine startup and shutdown	BAAQMD condition #18310, Part 27b	C	CEM	X	
NOx	BAAQMD condition #18310, part 20a	Y	19.2 lb/hr for each turbine/HRSG powertrain, except during turbine startup and shutdown	BAAQMD condition #18310, Part 31	P/A	Source Test at maximum load	X	
NOx	BAAQMD condition #18310, part 20a	Y	0.00904 lb/MM BTU for each turbine/HRSG powertrain, except during turbine startup and shutdown	BAAQMD condition #18310, Part 27b	C	CEM	X	
NOx	BAAQMD condition #18310, part 20a	Y	0.00904 lb/MM BTU for each turbine/HRSG powertrain, except during turbine startup and shutdown	BAAQMD condition #18310, Part 31	P/A	Source Test at maximum load	X	

Metcalf Energy Center
Title V CEMS Semi-Annual Monitoring Report
January 1, 2017 – June 30, 2017.

Type of Limit	Citation of Limit	FE Y/N	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
							Yes	No
NOx	BAAQMD condition #18310, part 20b	Y	2.5 ppmv, @ 15% O2, dry, for each tubine/HRSG powertrain, 1-hr average except during turbine startup and shutdown	BAAQMD condition #18310, Part 31	P/A	Source Test at maximum load	X	
NOx	BAAQMD condition #18310, part 20b	Y	2.5 ppmv, @ 15% O2, dry, for each tubine/HRSG powertrain, 1-hr average except during turbine startup and shutdown	BAAQMD condition #18310, Part 27b	C	CEM	X	
NOx	BAAQMD condition #18310, part 21	Y	240 lb/gas turbine start-up	BAAQMD condition #18310, Part 27b	C	CEM	X	
NOx	BAAQMD condition #18310, part 21	Y	480 lb/hr during gas turbine cold start-up or combustor tuning period	BAAQMD condition #18310, Part 27b	C	CEM	X	
NOx	BAAQMD condition #18310, part 21	Y	80 lb/gas turbine shutdown	BAAQMD condition #18310, Part 27b	C	CEM	X	
NOx	BAAQMD condition #18310, part 24a	Y	1362.6 lb/day for S-1, S-3 Gas Turbines and S-2, S-4 HRSGs, combined	BAAQMD condition #18310, Part 27b	C	CEM	X	
NOx	BAAQMD condition #18310, part 25a	Y	123.4 ton/yr for S-1, S-3 Gas Turbines and S-2, S-4 HRSGs, combined (including emissions from commissioning period)	BAAQMD condition #18310, Part 27b	C	CEM	X	
CO	BAAQMD condition #18310, part 20c	Y	18.7 lb/hr, for each turbine/HRSG powertrain, except during turbine startup and shutdown	BAAQMD condition #18310, Part 31	P/A	Source Test at maximum load and minimum load	X	
CO	BAAQMD condition #18310, part 20c	Y	18.7 lb/hr, for each turbine/HRSG powertrain, except during turbine startup and shutdown	BAAQMD condition #18310, Part 27b	C	CEM	X	

Metcalf Energy Center
Title V CEMS Semi-Annual Monitoring Report
January 1, 2017 – June 30, 2017.

Type of Limit	Citation of Limit	FE Y/N	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
							Yes	No
CO	BAAQMD condition #18310, part 20d	Y	0.0088 lb/MM BTU for each turbine/HRSG powertrain, except during turbine startup and shutdown	BAAQMD condition #18310, Part 31	P/A	Source Test at maximum load and minimum load	X	
CO	BAAQMD condition #18310, part 20d	Y	0.0088 lb/MM BTU for each turbine/HRSG powertrain, except during turbine startup and shutdown	BAAQMD condition #18310, Part 27b	C	CEM	X	
CO	BAAQMD condition #18310, part 20d	Y	4 ppmv @ 15% O2, dry, for each turbine/HRSG powertrain, 3-hr average, except during turbine startup and shutdown	BAAQMD condition #18310, Part 31	P/A	Source Test at maximum load and minimum load	X	
CO	BAAQMD condition #18310, part 20d	Y	4 ppmv @ 15% O2, dry, for each turbine/HRSG powertrain, 3-hr average, except during turbine startup and shutdown	BAAQMD condition #18310, Part 27b	C	CEM	X	
CO	BAAQMD condition #18310, part 20d	Y	4 ppmv @ 15% O2, dry, for each turbine/HRSG powertrain, 3-hr average, except during turbine startup and shutdown	40 CFR 64.3 (b)(4)(ii)	At least 4 times per hour (CAM Plan)	CEM	X	
CO	BAAQMD condition #18310, part 21	Y	2,514 lb/gas turbine startup	BAAQMD condition #18310, Part 27b	C	CEM	X	
CO	BAAQMD condition #18310, part 21	Y	5028 lb/hr during gas turbine cold start-up or combustor tuning period	BAAQMD condition #18310, Part 27b	C	CEM	X	
CO	BAAQMD condition #18310, part 21	Y	902 lb/gas turbine shutdown	BAAQMD condition #18310, Part 27b	C	CEM	X	
CO	BAAQMD condition #18310, part 24b	Y	7,891.1 lb/day for S-1, S-3 gas turbines and S-2, S-4 HRSGs, combined	BAAQMD condition #18310, Part 27b	C	CEM	X	

Metcalf Energy Center
Title V CEMS Semi-Annual Monitoring Report
January 1, 2017 – June 30, 2017.

Type of Limit	Citation of Limit	FE Y/N	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
							Yes	No
CO	BAAQMD condition #18310, part 25b	Y	588 ton/yr for S-1, S-3 gas turbines and S-2, S-4 HRSGs, combined (includes emissions from commissioning period)	BAAQMD condition #18310, Part 27b	C	CEM	X	
CO_2		Y	None	40 CFR 75.10	C	fuel flow monitor and CO2 calculation	X	
SO_2	BAAQMD 9-1-301	Y	GLC[1] of 0.5 ppm for 3 min or 0.25 ppm for 60 min or 0.05 ppm for 24 hours		N		X	
SO_2	BAAQMD 9-1-302	Y	300 ppm (dry)		N		X	
SO_2	NSPS 40 CFR 60.333(a)	Y	0.015% (vol.) @ 15% O_2 (dry)	NSPS 40 CFR 60.334(h)	N		X	
SO_2	NSPS 40 CFR 60.333(b)	Y	Total sulfur content of fuel not to exceed 0.8 percent by weight (8000 ppmw)	NSPS 40 CFR 60.334(h)(3)(ii) and BAAQMD condition #18310, Part 45	P/M	Fuel sulfur content testing	X	
SO_2		Y	None	40 CFR 75.11, 40 CFR 75, Appendix D, part 2.3	P/A	Fuel measurements, calculations	X	
SO2	BAAQMD condition #18310, part 20g	Y	1.28 lb/hr, for each turbine/HRSH powertrain	BAAQMD condition #18310, part 31	P/A	Source test at maximum load	X	
SO2	BAAQMD condition #18310, part 20g	Y	1.28 lb/hr, for each turbine/HRSH powertrain	BAAQMD condition #18310, part 28	P/D	Records, calculations	X	
SO2	BAAQMD condition #18310, part 20g	Y	0.0006lb/MM BTU, for each turbine/HRSG powertrain	BAAQMD condition #18310, part 31	P/A	Source test at maximum load	X	

Metcalf Energy Center
Title V CEMS Semi-Annual Monitoring Report
January 1, 2017 – June 30, 2017.

Type of Limit	Citation of Limit	FE Y/N	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
							Yes	No
SO2	BAAQMD condition #18310, part 20g	Y	0.0006lb/MM BTU, for each turbine/HRSG powertrain	BAAQMD condition #18310, part 28	P/D	Records, calculations	X	
SO2	BAAQMD condition #18310, part 24e	Y	57.9 lb/day for each turbine/HRSG powertrain	BAAQMD condition #18310, part 28	P/D	Records, calculations	X	
SO2	BAAQMD condition #18310, part 25e	Y	10.6 ton /yr for each turbine/HRSG powertrain (includes emissions from commissioning period)	BAAQMD condition #18310, part 28	P/D	Records, calculations	X	
Opacity	BAAQMD 6-1-301	N	> Ringelmann No. 1 for no more than 3 minutes in any hour		N		X	
Opacity	SIP 6-301	Y	> Ringelmann No. 1 for no more than 3 minutes in any hour		N		X	
FP	BAAQMD 6-1-310.3	N	0.15 grain/dscf @ 6% O2		N		X	
FP	SIP 6-310.3	Y	0.15 grain/dscf @ 6% O2		N		X	
PM_{10}	BAAQMD condition #18310, part 20h	Y	9 lb/hr, for each turbine/HRSG powertrain	BAAQMD condition #18310, part 31	P/A	Source test at maximum load	X	
PM_{10}	BAAQMD condition #18310, part 20h	Y	0.00452 lb/MM BTU, for each turbine/HRSG powertrain	BAAQMD condition #18310, part 31	P/A	Source test at maximum load	X	
PM_{10}	BAAQMD condition #18310, part 24d	Y	510 lb/day for S-1, S-3 Gas turbines and S-2, S-4 HRSGs, combined	BAAQMD condition #18310, part 28	P/D	Records, calculations	X	
PM_{10}	BAAQMD condition #18310, part 25d	Y	83.34 ton/yr for S-1, S-3 Gas turbines and S-2, S-4 HRSGs, combined (including emissions from commissioning period)	BAAQMD condition #18310, part 28	P/D	Records, calculations	X	

Metcalf Energy Center
Title V CEMS Semi-Annual Monitoring Report
January 1, 2017 – June 30, 2017.

Type of Limit	Citation of Limit	FE Y/N	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
							Yes	No
POC	BAAQMD condition #18310, part 20f	Y	2.7 lb/hr (as CH4) for each turbine/HRSG powertrain except during turbine startup and shut down	BAAQMD condition #18310, part 31	P/A	Source test at maximum load	X	
POC	BAAQMD condition #18310, part 20f	Y	0.00126 lb/MM BTU (as CH4) for each turbine/HRSG powertrain except during turbine startup and shut down	BAAQMD condition #18310, part 31	P/A	Source test at maximum load	X	
POC	BAAQMD condition #18310, part 21	Y	48 lb/gas turbine startup	BAAQMD condition #18310, part 28	P/D	Records, calculations	X	
POC	BAAQMD condition #18310, part 21	Y	16 lb/gas turbine shutdown	BAAQMD condition #18310, part 28	P/D	Records, calculations	X	
POC	BAAQMD condition #18310, part 21	Y	96 lb/hr during gas turbine cold start up or combustor tuning period	BAAQMD condition #18310, part 28	P/D	Records, calculations	X	
POC	BAAQMD condition #18310, part 24c	Y	230.2 lb/day (as CH4) for S-1, S-3 gas turbines and S-2, S-4 HRSGs, combined	BAAQMD condition #18310, part 28	P/D	Records, calculations	X	
POC	BAAQMD condition #18310, part 25c	Y	28 ton/yr) for S-1, S-3 gas turbines and S-2, S-4 HRSGs, combined (including emissions from commissioning period)	BAAQMD condition #18310, part 28	P/D	Records, calculations	X	
NH_3	BAAQMD condition #18310, part 20e	N	5 ppmv, @ 15% O2 dry, averaged over 3 hrs for each turbine/HRSG powertrain, except during turbine startup and shutdown	BAAQMD condition #18310, part 27c	C	Ammonia injection rate monitor	X	
Formal-dehyde	BAAQMD condition #18310, part 26a	N	3796 lb/yr for S-1, S-3 gas turbines and S-2, S-4 HRSGs, combined	BAAQMD condition #18310, part 29	P/D	Records, calculations	X	

Metcalf Energy Center
Title V CEMS Semi-Annual Monitoring Report
January 1, 2017 – June 30, 2017.

Type of Limit	Citation of Limit	FE Y/N	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
							Yes	No
Formal-dehyde	BAAQMD condition #18310, part 26a	N	3796 lb/yr for S-1, S-3 gas turbines and S-2, S-4 HRSGs, combined	BAAQMD condition #18310, part 33	P/every two years on P-1 or P-2	Source Test	X	
Benzene	BAAQMD condition #18310, part 26b	N	480 lb/yr for S-1, S-3 gas turbines and S-2, S-4 HRSGs, combined	BAAQMD condition #18310, part 29	P/D	Records, calculations	X	
Benzene	BAAQMD condition #18310, part 26b	N	480 lb/yr for S-1, S-3 gas turbines and S-2, S-4 HRSGs, combined	BAAQMD condition #18310, part 33	P/every two years on P-1 or P-2	Source Test	X	
Specific PAH Compounds	BAAQMD condition #18310, part 26c	N	22.8 lb/yr for S-1, S-3 gas turbines and S-2, S-4 HRSGs, combined	BAAQMD condition #18310, part 29	P/D	Records, calculations	X	
Specific PAH Compounds	BAAQMD condition #18310, part 26c	N	22.8 lb/yr for S-1, S-3 gas turbines and S-2, S-4 HRSGs, combined	BAAQMD condition #18310, part 33	P/every two years on P-1 or P-2	Source Test	X	
Heat input limit	BAAQMD condition #18310, part 14	Y	2,124 MM BTU/hr (HHV), 3-hr average for each turbine/HRSG powertrain	BAAQMD condition #18310, part 27a	C	Fuel meter, firing monitor, calculations	X	
Heat input limit	BAAQMD condition #18310, part 15	Y	49,908 MM BTU/calendar day (HHV), for each turbine/HRSG powertrain	BAAQMD condition #18310, part 27a	C	Fuel meter, firing monitor, calculations	X	
Heat input limit	BAAQMD condition #18310, part 16	Y	35,274,060 MM BTU/yr (HHV) for S-1, S-3 gas turbines and S-2, S-4 HRSGs, combined	BAAQMD condition #18310, part 27a	C	Fuel meter, firing monitor, calculations	X	
Cold Start-Up, Combustor Tuning Firing Limit	BAAQMD condition #18310, part 48	Y	30 firing hours per year for S-1 and S-3 gas turbines, combined for purposes of cold start-up or combustor tuning	BAAQMD condition #18310, part 49	P/E	Recordkeeping	X	

Metcalf Energy Center
Title V CEMS Semi-Annual Monitoring Report
January 1, 2017 – June 30, 2017.

Table VII - B

Applicable Limits and Compliance Monitoring Requirements

S-3, Heat Recovery Steam Generator #1

S-4, Heat Recovery Steam Generator #2

Type of Limit	Citation of Limit	FE Y/N	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
							Yes	No
NOx	BAAQMD 9-9-301.1.3	N	9 ppmv @ 15% O2, dry	BAAQMD 9-9-501	C	CEM	X	
NOx	SIP 9-9-301.3	Y	9 ppmv @ 15% O2, dry	SIP 9-9-501	C	CEM	X	
NOx	BAAQMD 9-9-301.2	N	0.15 LB/MMBTU or 5 ppmv	BAAQMD 9-9-501	C	CEM	X	
NOx	NSPS, 40 CFR 60.44b (a)(4)(i)	Y	0.2 lb/ MM BTU except, during start-up, shutdown or malfuntion	NSPS 40 CFR 60.48b (b)(2) and BAAQMD Condition #18310, part 27b	C	CEM	X	
NOx	NSPS, 40 CFR 60.332 (a)(1)	Y	75 ppmv @ 15% O2, dry, 4-hour rolling average	NSPS 40 CFR 60.334(c.) and BAAQMD Condition #18310, part 27b	C	CEM	X	
NOx		Y	None	40 CFR 75.10	C	CEM	X	
NOx	BAAQMD condition #18310, part 20a	Y	19.2 lb/hr for each turbine/HRSG powertrain, except during turbine startup and shutdown	BAAQMD condition #18310, Part 27b	C	CEM	X	
NOx	BAAQMD condition #18310, part 20a	Y	19.2 lb/hr for each turbine/HRSG powertrain, except during turbine startup and shutdown	BAAQMD condition #18310, Part 31	P/A	Source Test at maximum load	X	
NOx	BAAQMD condition #18310, part 20a	Y	0.00904 lb/MM BTU for each turbine/HRSG powertrain, except during turbine startup and shutdown	BAAQMD condition #18310, Part 27b	C	CEM	X	

Metcalf Energy Center
Title V CEMS Semi-Annual Monitoring Report
January 1, 2017 – June 30, 2017.

Type of Limit	Citation of Limit	FE Y/N	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
							Yes	No
NOx	BAAQMD condition #18310, part 20a	Y	0.00904 lb/MM BTU for each turbine/HRSG powertrain, except during turbine startup and shutdown	BAAQMD condition #18310, Part 31	P/A	Source Test at maximum load	X	
NOx	BAAQMD condition #18310, part 20b	Y	2.5 ppmv, @ 15% O2, dry, for each tubine/HRSG powertrain, 1-hr average except during turbine startup and shutdown	BAAQMD condition #18310, Part 31	P/A	Source Test at maximum load	X	
NOx	BAAQMD condition #18310, part 20b	Y	2.5 ppmv, @ 15% O2, dry, for each tubine/HRSG powertrain, 1-hr average except during turbine startup and shutdown	BAAQMD condition #18310, Part 27b	C	CEM	X	
NOx	BAAQMD condition #18310, part 24a	Y	1362.6 lb/day for S-1, S-3 Gas Turbines and S-2, S-4 HRSGs, combined	BAAQMD condition #18310, Part 27b	C	CEM	X	
NOx	BAAQMD condition #18310, part 25a	Y	123.4 ton/yr for S-1, S-3 Gas Turbines and S-2, S-4 HRSGs, combined (including emissions from commissioning period)	BAAQMD condition #18310, Part 27b	C	CEM	X	
CO	BAAQMD condition #18310, part 20c	Y	18.7 lb/hr, for each turbine/HRSG powertrain, except during turbine startup and shutdown	BAAQMD condition #18310, Part 31	P/A	Source Test at maximum load and minimum load	X	
CO	BAAQMD condition #18310, part 20c	Y	18.7 lb/hr, for each turbine/HRSG powertrain, except during turbine startup and shutdown	BAAQMD condition #18310, Part 27b	C	CEM	X	
CO	BAAQMD condition #18310, part 20d	Y	0.0088 lb/MM BTU for each turbine/HRSG powertrain, except during turbine startup and shutdown	BAAQMD condition #18310, Part 31	P/A	Source Test at maximum load and minimum load	X	

Metcalf Energy Center
Title V CEMS Semi-Annual Monitoring Report
January 1, 2017 – June 30, 2017.

Type of Limit	Citation of Limit	FE Y/N	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
							Yes	No
CO	BAAQMD condition #18310, part 20d	Y	0.0088 lb/MM BTU for each turbine/HRSG powertrain, except during turbine startup and shutdown	BAAQMD condition #18310, Part 27b	C	CEM	X	
CO	BAAQMD condition #18310, part 20d	Y	4 ppmv @ 15% O2, dry, for each turbine/HRSG powertrain, 3-hr average, except during turbine startup and shutdown	BAAQMD condition #18310, Part 31	P/A	Source Test at maximum load and minimum load	X	
CO	BAAQMD condition #18310, part 20d	Y	4 ppmv @ 15% O2, dry, for each turbine/HRSG powertrain, 3-hr average, except during turbine startup and shutdown	BAAQMD condition #18310, Part 27b	C	CEM	X	
CO	BAAQMD condition #18310, part 24b	Y	7,891.1 lb/day for S-1, S-3 gas turbines and S-2, S-4 HRSGs, combined	BAAQMD condition #18310, Part 27b	C	CEM	X	
CO	BAAQMD condition #18310, part 25b	Y	588 ton/yr for S-1, S-3 gas turbines and S-2, S-4 HRSGs, combined (includes emissions from commissioning period)	BAAQMD condition #18310, Part 27b	C	CEM	X	
CO_2		Y	None	40 CFR 75.10	C	fuel flow monitor and CO2 calculation	X	
SO_2	BAAQMD 9-1-301	Y	GLC[1] of 0.5 ppm for 3 min or 0.25 ppm for 60 min or 0.05 ppm for 24 hours		N		X	
SO_2	BAAQMD 9-1-302	Y	300 ppm (dry)		N		X	
SO_2	NSPS 40 CFR 60.333(a)	Y	0.015% (vol.) @ 15% O_2 (dry)	NSPS 40 CFR 60.334(h)	N		X	

Metcalf Energy Center
Title V CEMS Semi-Annual Monitoring Report
January 1, 2017 – June 30, 2017.

Type of Limit	Citation of Limit	FE Y/N	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
							Yes	No
SO_2	NSPS 40 CFR 60.333(b)	Y	Total sulfur content of fuel not to exceed 0.8 percent by weight (8000 ppmw)	NSPS 40 CFR 60.334(h)(3)(ii) and BAAQMD condition #18310, Part 45	P/M	Fuel sulfur content testing	X	
SO_2		Y	None	40 CFR 75.11, 40 CFR 75, Appendix D, part 2.3	P/A	Fuel measurements, calculations	X	
SO2	BAAQMD condition #18310, part 20g	Y	1.28 lb/hr, for each turbine/HRSH powertrain	BAAQMD condition #18310, part 31	P/A	Source test at maximum load	X	
SO2	BAAQMD condition #18310, part 20g	Y	1.28 lb/hr, for each turbine/HRSH powertrain	BAAQMD condition #18310, part 28	P/D	Records, calculations	X	
SO2	BAAQMD condition #18310, part 20g	Y	0.0006lb/MM BTU, for each turbine/HRSG powertrain	BAAQMD condition #18310, part 31	P/A	Source test at maximum load	X	
SO2	BAAQMD condition #18310, part 20g	Y	0.0006lb/MM BTU, for each turbine/HRSG powertrain	BAAQMD condition #18310, part 28	P/D	Records, calculations	X	
SO2	BAAQMD condition #18310, part 24e	Y	57.9 lb/day for each turbine/HRSG powertrain	BAAQMD condition #18310, part 28	P/D	Records, calculations	X	
SO2	BAAQMD condition #18310, part 25e	Y	10.6 ton /yr for each turbine/HRSG powertrain (includes emissions from commissioning period)	BAAQMD condition #18310, part 28	P/D	Records, calculations	X	
Opacity	BAAQMD 6-1-301	N	> Ringelmann No. 1 for no more than 3 minutes in any hour		N		X	
Opacity	SIP 6-301	Y	> Ringelmann No. 1 for no more than 3 minutes in any hour		N		X	

Metcalf Energy Center
Title V CEMS Semi-Annual Monitoring Report
January 1, 2017 – June 30, 2017.

Type of Limit	Citation of Limit	FE Y/N	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
							Yes	No
FP	BAAQMD 6-1-310.3	N	0.15 grain/dscf @ 6% O2		N		X	
FP	SIP 6-310.3	Y	0.15 grain/dscf @ 6% O2		N		X	
PM	NSPS 40 CFR 60.42a (b)	Y	< 20% opacity, 6 minute average, except one six minute period/hr up to 27% opacity		N		X	
PM_{10}	BAAQMD condition #18310, part 20h	Y	9 lb/hr, for each turbine/HRSG powertrain	BAAQMD condition #18310, part 31	P/A	Source test at maximum load	X	
PM_{10}	BAAQMD condition #18310, part 20h	Y	0.00452 lb/MM BTU, for each turbine/HRSG powertrain	BAAQMD condition #18310, part 31	P/A	Source test at maximum load	X	
PM_{10}	BAAQMD condition #18310, part 24d	Y	510 lb/day for S-1, S-3 Gas turbines and S-2, S-4 HRSGs, combined	BAAQMD condition #18310, part 24	P/D	Records, calculations	X	
PM_{10}	BAAQMD condition #18310, part 25d	Y	83.34 ton/yr for S-1, S-3 Gas turbines and S-2, S-4 HRSGs, combined (including emissions from commissioning period)	BAAQMD condition #18310, part 25	P/D	Records, calculations	X	
POC	BAAQMD condition #18310, part 20f	Y	2.7 lb/hr (as CH4) for each turbine/HRSG powertrain except during turbine startup and shut down	BAAQMD condition #18310, part 31	P/A	Source test at maximum load	X	
POC	BAAQMD condition #18310, part 20f	Y	0.00126 lb/MM BTU (as CH4) for each turbine/HRSG powertrain except during turbine startup and shut down	BAAQMD condition #18310, part 31	P/A	Source test at maximum load	X	
POC	BAAQMD condition #18310, part 24c	Y	230.2 lb/day (as CH4) for S-1, S-3 gas turbines and S-2, S-4 HRSGs, combined	BAAQMD condition #18310, part 28	P/D	Records, calculations	X	

Metcalf Energy Center
Title V CEMS Semi-Annual Monitoring Report
January 1, 2017 – June 30, 2017.

Type of Limit	Citation of Limit	FE Y/N	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
							Yes	No
POC	BAAQMD condition #18310, part 25c	Y	28 ton/yr) for S-1, S-3 gas turbines and S-2, S-4 HRSGs, combined (including emissions from commissioning period)	BAAQMD condition #18310, part 28	P/D	Records, calculations	X	
NH_3	BAAQMD condition #18310, part 20e	N	5 ppmv, @ 15% O2 dry, averaged over 3 hrs for each turbine/HRSG powertrain, except during turbine startup and shutdown	BAAQMD condition #18310, part 27c	C	Ammonia injection rate monitor	X	
Formalde-hyde	BAAQMD condition #18310, part 26a	N	3796 lb/yr for S-1, S-3 gas turbines and S-2, S-4 HRSGs, combined	BAAQMD condition #18310, part 29	P/D	Records, calculations	X	
Formalde-hyde	BAAQMD condition #18310, part 26a	N	3796 lb/yr for S-1, S-3 gas turbines and S-2, S-4 HRSGs, combined	BAAQMD condition #18310, part 33	P/every two years on P-1 or P-2	Source Test	X	
Benzene	BAAQMD condition #18310, part 26b	N	480 lb/yr for S-1, S-3 gas turbines and S-2, S-4 HRSGs, combined	BAAQMD condition #18310, part 29	P/D	Records, calculations	X	
Benzene	BAAQMD condition #18310, part 26b	N	480 lb/yr for S-1, S-3 gas turbines and S-2, S-4 HRSGs, combined	BAAQMD condition #18310, part 33	P/every two years on P-1 or P-2	Source Test	X	
Specific PAH Compounds	BAAQMD condition #18310, part 26c	N	22.8 lb/yr for S-1, S-3 gas turbines and S-2, S-4 HRSGs, combined	BAAQMD condition #18310, part 29	P/D	Records, calculations	X	
Specific PAH Compounds	BAAQMD condition #18310, part 26c	N	22.8 lb/yr for S-1, S-3 gas turbines and S-2, S-4 HRSGs, combined	BAAQMD condition #18310, part 33	P/every two years on P-1 or P-2	Source Test	X	
Heat input limit	BAAQMD condition #18310, part 14	Y	2,124 MM BTU/hr (HHV), 3-hr average for each turbine/HRSG powertrain	BAAQMD condition #18310, part 27a	C	Fuel meter, firing monitor, calculations	X	

Metcalf Energy Center
Title V CEMS Semi-Annual Monitoring Report
January 1, 2017 – June 30, 2017.

Type of Limit	Citation of Limit	FE Y/N	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
							Yes	No
Heat input limit	BAAQMD condition #18310, part 15	Y	49,908 MM BTU/calendar day (HHV), for each turbine/HRSG powertrain	BAAQMD condition #18310, part 27a	C	Fuel meter, firing monitor, calculations	X	
Heat input limit	BAAQMD condition #18310, part 16	Y	35,274,060 MM BTU/yr (HHV) for S-1, S-3 gas turbines and S-2, S-4 HRSGs, combined	BAAQMD condition #18310, part 27a	C	Fuel meter, firing monitor, calculations	X	
Prohibited firing	BAAQMD condition #18310, part 17	Y	Each HRSG duct burner may not be fired unless its associated gas turbine is being fired	BAAQMD condition #18310, part 27a	C	Fuel meter, firing monitor, calculations	X	

Metcalf Energy Center
Title V CEMS Semi-Annual Monitoring Report
January 1, 2017 – June 30, 2017.

Table VII – C

Applicable Limits and Compliance Monitoring Requirements

S-5 Cooling Tower

Type of Limit	Citation of Limit	FE Y/N	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
							Yes	No
Opacity	BAAQMD 6-1-301	N	>Ringelmann No.1 for no more than 3 minutes in any hour		N		X	
FP	BAAQMD 6-1-310	N	0.15 gr/dscf		N		X	
Opacity	SIP 6-301	Y	>Ringelmann No.1 for no more than 3 minutes in any hour		N		X	
FP	SIP 6-310	Y	0.15 gr/dscf		N		X	
Drift Rate	BAAQMD Condition #18310, part 46	Y	0.0005%	BAAQMD Condition #18310, part 46	P	Initial Source Test	X	
Total Dissolved Soilds	BAAQMD Condition #18310, part 46	Y	5438 ppmw (mg/l)	BAAQMD Condition #18310, part 46	P/D	Sampling and Testing of cooling tower water	X	

Metcalf Energy Center
Title V CEMS Semi-Annual Monitoring Report
January 1, 2017 – June 30, 2017.

Table VII – D

Applicable Limits and Compliance Monitoring Requirements

S-6 STATIONARY STANDBY GENERATOR SET

Type of Limit	Citation of Limit	FE Y/N	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
							Yes	No
Opacity	BAAQMD 6-1-301	N	>Ringelmann No.1 for no more than 3 minutes in any hour		N		SOURCE NOT COMMISSIONED	
Opacity	SIP 6-301	Y	>Ringelmann No.1 for no more than 3 minutes in any hour		N			
FP	BAAQMD 6-1-310.3	N	0.15 gr/dscf @ 6% O2		N			
FP	SIP 6-310.3	Y	0.15 gr/dscf @ 6% O2		N			
SO_2	BAAQMD 9-1-301	Y	GLC[1] of 0.5 ppm for 3 min or 0.25 ppm for 60 min or 0.05 ppm for 24 hours		N			
SO_2	BAAQMD 9-1-302	Y	300 ppm (dry)		N			
Heat Input Limit	BAAQMD Condition #22231 part 1	Y	14.1 MM BTU/hr		N			
Reliability Related activities	BAAQMD Condition #22231 part 2	Y	100 hours per calendar year	BAAQMD Condition #22231 part 6	P/E	Recordkeeping		
NOx, CO and POC	BAAQMD Condition #22231 part 3	Y	1.0 g NOx/bhp-hr 2.75 g CO/bhp-hr 1.0 g POC/bhp-hr		N			

Metcalf Energy Center
Title V CEMS Semi-Annual Monitoring Report
January 1, 2017 – June 30, 2017.

Table VII – E

Applicable Limits and Compliance Monitoring Requirements

S-7 Fire Pump Diesel Engine

Type of Limit	Citation of Limit	FE Y/N	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
							Yes	No
Opacity	BAAQMD 6-1-301	N	>Ringelmann No.2 for no more than 3 minutes in any hour		N		X	
Opacity	SIP 6-301	Y	>Ringelmann No.2 for no more than 3 minutes in any hour		N		X	
FP	BAAQMD 6-1-310.3	N	0.15 gr/dscf @ 6% O2		N		X	
FP	SIP 6-310.3	Y	0.15 gr/dscf @ 6% O2		N		X	
SO_2	BAAQMD 9-1-301	Y	GLC[1] of 0.5 ppm for 3 min or 0.25 ppm for 60 min or 0.05 ppm for 24 hours		N		X	
Fuel Sulfur Content	BAAQMD 9-1-304	Y	Sulfur Content ≤ 0.5% by weight		N		X	
SO_2	BAAQMD Condition #19610, part 39	N	Sulfur content of fuel less than 0.05% by weight	BAAQMD Condition #19610, part 39	P/E		X	
Reliability Related activities	BAAQMD Condition #21917 part 1	Y	30 hours per calendar year	BAAQMD Condition #21917 part 2, 3	P/E	Totalizing Meter, record keeping	X	